

Question: Is a state license required for a Talbot County HVACR permit?

Answer: Yes, master restricted or better

Question: What code is Talbot County going to follow for HVAC installation?

Answer: 2003 IRC for residential and 2003 IMC for commercial/industrial

Question: Who may call in for an HVAC inspection?

Answer: Master restricted or designated individual

Question: Is a Manual J and duct design required for new installation of HVACR equipment?

Answer: Yes, at the time of HVACR application

Question: Can you change HVACR contractors after a project has begun and if yes, what is the procedure?

Answer: Yes, a change over form is required and may be obtained from our office

Question: When a project changes in scope what is required to amend the HVACR permit?

Answer: Manual J and duct design will be required with amendment

Question: If I have 3 condensing units outside and 5 units mounted inside, how many systems will I be charged with?

Answer: 3

Question: Can you run the condensate line into your septic line?

Answer: No, other alternatives are available such as:

1. run to sump pit with mechanical means of discharge
2. oversize condensate line to daylight

Question: What latitude does an HVAC installer have in applications in older homes for meeting appliance clearances?

Answer: Minimum would be per manufacturer specs

Question: What are the minimum requirements of CFM air flow to different rooms?

Answer: Per Manual J calculation

Question: Are boilers considered an appliance for HVACR purposes?

Answer: Yes

Question: Are there clearance requirements for equipment installation of appliances in new homes?

Answer: Yes, per manufacturer requirements and/or the applicable code

Question: What R-values will be required for ductwork?

Answer: 2003 IRC requires R-5 minimum for inside building envelope and R-8 outside building envelope