

## **SETBACK REQUIREMENTS FOR ENVIRONMENTAL HEALTH**

### **SDA**

- must be 15 feet from property line
- must be 100 feet from well
- SDA and tile fields must be 20 feet from foundation

### **WELL**

- must be a minimum of 10 feet from property line
- must be 50 feet from septic tank
- must be 30 feet from foundation

### **SEPTIC TANK**

- must be at least 6 feet from foundation (prefer 10 feet)

### **MISCELLANEOUS**

- 75 feet of tile field per bedroom
- 2500 square feet per bedroom for SDA
- in-ground pool must be 25 feet from SDA/Septic
- in-ground pool – well must be accessible for repair/replacement

